



DASNY

ANDREW M. CUOMO
Governor

ALFONSO L. CARNEY, JR.
Chair

GERRARD P. BUSHELL, Ph.D.
President & CEO

April 12, 2018

To: All Bidders

Subject: DASNY IFB # 595 - Addendum No. 1
Description: Fabricate and Install Interior & Exterior Signage
Project: Hutchings Psychiatric Center
Bid Due Date: April 19, 2018 2:30 PM

Dear Sir / Madam:

Enclosed please find Addendum No. 1 to the above referenced Invitation for Bids.

Please review the information contained in this Addendum carefully. A copy of this document, bearing an original signature must be attached to your submission in response to the Invitation for Bids.

If you have any questions regarding this document, please contact Peter Bujanow at (518) 257-3080.

Sincerely,

Louis R. Cirelli, Jr., D.B.A., P.E., CMQ/OE
Director, Procurement

Enclosures

CORPORATE HEADQUARTERS
515 Broadway
Albany, NY 12207-2964

T 518-257-3000
F 518-257-3100

NEW YORK CITY OFFICE
One Penn Plaza, 52nd Floor
New York, NY 10119-0098

T 212-273-5000
F 212-273-5121

BUFFALO OFFICE
539 Franklin Street
Buffalo, NY 14202-1109

T 716-884-9780
F 716-884-9787

DORMITORY AUTHORITY STATE OF NEW YORK

WE FINANCE, BUILD AND DELIVER.

www.dasny.org

ADDENDUM NO. 1
DASNY Invitation for Bids No. 595
Fabricate and Install Interior & Exterior Signage
Hutchings Psychiatric Center
BID DUE DATE: April 19, 2018 2:30 PM

Specifics of the Addendum:

CLARIFICATIONS – ADA COMPLIANCE:

Please refer to the following text and attached photo contained in the pdf file for ADA compliance clarifications on the specified sign:

The sign is comprised of three (3) primary components: Lexan back plate, SSADA thermoformed copy, & Lexan front plate. The Lexan Front Plate covers the entire sign, with the exception of the SSADA section of the sign. The Lexan Front Plate is routed out to allow the SSADA section to be exposed. The SSADA section therefore remains a tactile layer.

In addition, the government Access Board has responded to our inquiry regarding ADA compliance of the signs in question and they have confirmed that the sign is ADA compliant.

Per the Access Board: “Nothing in the ADA Standards controls the height of raised borders or decorative elements.”



Sign Sample_Basis of
Design.pdf

CLARIFICATIONS – MAIN BUILDING EXTERIOR SIGN DETAIL:

Please see below for excerpts from various sections of the Specification Document which outline the Main Building Exterior Sign in detail:

PART 2 – PRODUCTS

- 1) **SIGN STANDARDS-Exterior Main Building Sign**
 - a) **Sign Type 2/90 Sign Systems Main Building Exterior Sign**
 - i) **Mounting Option: Stud Mounting to Roof Facia**
 - c) **Main Building Exterior Name Sign:**
 - i. **Comprised of flat cut aluminum letters flush mounted on 1/2" x 1/2" silver painted aluminum bar**
 - ii. **Fabricated Letters: Height: 6", Depth: 3/8", Letter Style: Helvetica**



ADDENDUM NO. 1
DASNY Invitation for Bids No. 595
Fabricate and Install Interior & Exterior Signage
Hutchings Psychiatric Center
BID DUE DATE: April 19, 2018 2:30 PM

PART 3 – EXECUTION

- c) *Exterior Roof Facia Main Building Sign*
 - ii) *Mounting Method is intended for mounting the aluminum bar with letters on the metal facia of the roof using exterior grade hardware.*
 - iii) *Refer to the Main Building Exterior Sign Drawing for Install Location*
 - iv) *Method*
 - (1) *Installer to take field measurements to ensure proper fit.*
 - (2) *Mounting surface must be clean and dry to insure good adhesion.*
 - (3) *Installer to utilize templates provided by manufacturer.*
 - (4) *Install sign using extra-long hardware that is necessary to penetrate the 5/16” thick non-structural metal panel with 1 1/2” air space to affix the bar to the treated plywood substrate. The hardware must be stainless steel, galvanized steel, chrome plated or other non-corroding metal and concealed.*
 - (5) *Check for level, and apply firm pressure to fasteners for good adhesion*

All other terms and conditions of the original Invitation for Bids shall remain the same. This notice shall be signed and attached to the Invitation for Bids and shall form a part of your bid.

The below is to be completed by the submitter of the bid:

SIGNATURE: _____

PRINTED NAME: _____

FIRM: _____

ADDRESS: _____

E-MAIL ADDRESS: _____

DATE: _____

Recessed SSADA
Area; No Top Layer
of Lexan

