



DASNY

ADDENDUM NO.: 1

IFB or RFP NO.: Bid No. 617

Description: Furnish, Deliver and Install
Lockers

Project: NYCCT

Bid Opening Date: October 4, 2018

Specifics of the Addendum: Questions and Answers as part of the RFI and additional drawing has been included in the bid documents.

QUESTION/COMMENT: DASNY should consider changing the specifications for the stand-alone lockers (not in corridor recess) from knockdown lockers with 24 -gauge body parts to all-welded lockers with 18 -gauge body parts. First, all welded lockers are much more rugged and better able to withstand long term use. Further, for the same reasons 18 -gauge body parts, which are twice (2x) the thickness of 24 -gauge body parts, provide a much stronger long -term product. Taken together, providing an all-welded locker with 18 -gauge body parts will give City Tech a locker for many more years and at a comparable cost. If nothing else DASNY should make an all-welded 18 -gauge locker as an alternate bid.

RESPONSE: Bidders may submit "equals" or alternatives and provide documentation as to how it meets the specifications. If an alternative is suggested that does not meet the specifications and deviates from the provided specifications, documentation setting forth the deviations must be provided.

All other terms and conditions of the original Invitation for Bids or Request for Proposals shall remain the same. This notice shall be signed and attached to the Invitation for Bids and shall form a part of your bid.

The below is to be completed by the submitter of the bid:

SIGNATURE: _____

FIRM: _____

ADDRESS: _____

DATE: _____