



DASNY

ADDENDUM NO.: 4

IFB or RFP NO.: Re Bid No. 641

Bid Title: Furnish, Deliver and Install Laser
Curtains

Project: City College of New York

Bid Opening Date: October 16, 2019

Specifics of the Addendum: The purpose of this Addendum is to provide additional information in connection with the required interlock system.

Interlock System:

Lab curtains must have an interlock and "request to enter" switch inside and outside the curtain that will be tied to Interlock system (wired and installed into the curtains).

See attached.

All other terms and conditions of the original Invitation for Bid shall remain the same.



