



ADDENDUM NO.: 001

IFB NO.: 718

Description: Furnish and Deliver Door Hardware

Project: OMH – Hutchings PC – Furnish and Deliver Door Hardware

Bid Opening Date: February 25, 2022

Responses to Request for Information

Please see responses to the requests for information below:

- 1Q. I'd like to clarify the request is for the Body itself no handles, or if handles are wanted what style handle?
- 1A. Door handles are not required for this project, only the lock bodies are required.
- 2Q. We had submitted a proposal for the original bid invite, but then had to retract it as we discovered a material omission in our scope. I would greatly appreciate an explanation as to why this procurement was not awarded to the lowest of the remaining bidders and why it is rebidding?
- 2A. After the Bid Opening for Bid No. 713, OMH determined that the specified Model No. ML20932-KK-630-SEC-M92 Elec. Knob X RX Switch (Item No. 3) was incorrect and the correct lock body model required for their project is Model No. ML20932-LL630-SEC M91x M92. Due to this specification change, Bid No. 713 was canceled. Bid No 718 was issued with new Detailed Specifications, which includes Corbin Russwin Model No. ML20932-LL630-SEC M91x M92 Elec. Knob X RX Switch - Grade 1 Fail Secure Electrified Mortise Lock (Item No. 3).
- 3Q. The bid documents seem similar to the prior documents. If we are interested in bidding, should we resubmit all documents?
- 3A. The change in the Bid Documents is the change associated with the new Corbin Russwin Model No. That change is updated in the Detailed Specifications and Bid Breakdown and Schedule. The Bid Breakdown and Schedule. All Bid Documents should be resubmitted even if submitted as part of the previous Bid. We are unable to use documents previously submitted as Bid No. 713.
- 4Q. Is the below bid identical to Bid No. 713?
- 4A. No, Bid No. 718 is not identical to Bid No. 713. Please see the response to Question No. 2

5Q. Need to know if there is a cylinder required or requirement for Item No. 3 which is the Corbin Russwin ML20932-LL-630-SEC-M91-M92 lockset.

5A. No, cylinders are not required for Item No. 3. or any other items that are specified.

All other terms and conditions of the original Invitation for Bids or Request for Proposals shall remain the same. This notice shall be signed and attached to the Invitation for Bids and shall form a part of your bid.